



NOTES

1. ALL STEELWORK TO BE FABRICATED IN ACCORDANCE WITH AS 4100.
2. UNLESS NOTED OTHERWISE:
 - (a) ALL HOT ROLLED FLATS TO BE GRADE 250 MINIMUM IN ACCORDANCE WITH AS 1594.
 - (b) ALL HOT ROLLED SECTIONS TO BE GRADE 250 MINIMUM IN ACCORDANCE WITH AS 3679.
 - (c) ALL HOLLOW SECTIONS TO BE GRADE C350 IN ACCORDANCE WITH AS 1163.
3. AFTER FABRICATION, ALL BURRS AND SHARP EDGES TO BE REMOVED.
4. ALL WELDING TO BE IN ACCORDANCE WITH AS 1554.1.
 - (a) A WELDING PROCEDURE SHALL BE QUALIFIED BEFORE WELDING.
 - (b) A WELDING PROCEDURE SPECIFICATION (WPS) TO BE DEVELOPED FROM THE PROCEDURE QUALIFICATION RECORD (PQR).
 - (c) PRODUCE DOCUMENTARY EVIDENCE OF MACRO TEST, TENSILE AND BEND TEST IN ACCORDANCE WITH AS 1554.1
5. CONSUMABLES (ELECTRODES) SHALL BE MATCHED WITH THE STEEL TYPE IN COMPLIANCE WITH AS/NZS 1554.1 TABLE 4.6.1(A) & THE RELEVANT COLUMNS OF THE TABLE DEPENDING ON THE TYPE OF WELDING PROCESS BEING UNDERTAKEN.
6. UNLESS NOTED OTHERWISE:
 - (a) ALL WELDS SHALL BE 6mm CONTINUOUS FILLET WELDS, CATEGORY GP.
 - (b) BUTT WELDS SHALL BE CONTINUOUS FULL PENETRATION, CATEGORY SP.
 - (c) ALL WELDS TO BE CARRIED OUT IN THE SHOP UNLESS NOTED AS 'WELD ON SITE'.
7. WELDS SHALL BE INSPECTED TO AS/NZS 1554.1 CLAUSE 7.3 (VISUAL INSPECTION OF WORK) UNLESS THE WELDING PROCESS IS SUPERVISED AND CARRIED OUT BY QUALIFIED PERSONNEL AS DEFINED IN AS/NZS 1554.1 CLAUSE 4.12.1 AND CLAUSE 4.12.2.
8. AFTER FABRICATION, ALL WELDS TO BE CHIPPED FREE OF SLAG.
9. AFTER FABRICATION, ALL STEELWORK TO BE HOT DIP GALVANISED TO AS 4680. GALVANISING MINIMUM AVERAGE COATING THICKNESS AND MASS TO BE 125µm, 900g/m². AVERAGE THICKNESS SHALL BE DETERMINED IN ACCORDANCE WITH AS 2312.

SURFACE FINISH : THE GALVANISED COATING TO BE CONTINUOUS, ADHERENT, AS SMOOTH AND EVENLY DISTRIBUTED AS POSSIBLE, AND FREE FROM ANY DEFECT THAT IS DETRIMENTAL TO THE STATED END USE OF THE COATED ARTICLE. ANY REPARATION IS TO CARRIED OUT AS PER CLAUSE 8 OF AS 4680.

ADHESION : THE GALVANISED COATING SHALL BE SUFFICIENTLY ADHERENT TO WITHSTAND NORMAL HANDLING DURING TRANSPORT AND ERECTION.
10. AFTER GALVANISING, ALL HOLES TO BE CLEARED AND SHARP EDGES TO BE REMOVED.
11. WHERE THE GALVANISING FINISH HAS BEEN DAMAGED, AREA TO BE TREATED WITH COLD GALVANISING PAINT SIMILAR TO ZINCFIX. COATINGS TO BE APPLIED IN ACCORDANCE WITH THE MANUFACTURERS INSTRUCTIONS.
12. IF ANY MATERIAL DETAILED ON THE DRAWINGS IS CHANGED, PRIOR APPROVAL MUST BE OBTAINED FROM AUSGRID.
13. EXTENSION (AFTER GALVANISING) SHALL BE A CLEARANCE FIT ONTO A 42.4 OD STREET LIGHTING STANDARD SPIGOT.

CAD DRAWING DO NOT MANUALLY AMEND A M E N D M E N T S 5. DRAWING BORDER UPDATED. NOTES UPDATED TO CURRENT STANDARDS. C.SAWDY 8.01.2015 APPROVED : P. HUDSON	<p>CENTIMETRES ON ORIGINAL DRAWING AT SCALE 1:2</p>	<p>MECHANICAL DESIGN 570 GEORGE ST SYDNEY NSW 2000</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td>SCALE</td><td>1 : 1 , 5</td></tr> <tr><td>DESIGNED</td><td>K.E.M.</td></tr> <tr><td>DRAWN</td><td>R.G.</td></tr> <tr><td>CHECKED</td><td>K.E.M.</td></tr> <tr><td>APPROVED</td><td>J.H.</td></tr> <tr><td>DATE</td><td>18.11.1985</td></tr> <tr><td>PROJECT NUMBER</td><td>21770</td></tr> <tr><td>PROJTRAK NUMBER</td><td></td></tr> </table>	SCALE	1 : 1 , 5	DESIGNED	K.E.M.	DRAWN	R.G.	CHECKED	K.E.M.	APPROVED	J.H.	DATE	18.11.1985	PROJECT NUMBER	21770	PROJTRAK NUMBER		<p>STREET LIGHTING 1m OUTREACH EXTENSION ARRANGEMENT AND DETAILS</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>SIZE</td> <td>DRAWING No</td> <td>SHEET</td> <td>AMD</td> </tr> <tr> <td>A2</td> <td>65411</td> <td>1</td> <td>5</td> </tr> </table>	SIZE	DRAWING No	SHEET	AMD	A2	65411	1	5
SCALE	1 : 1 , 5																											
DESIGNED	K.E.M.																											
DRAWN	R.G.																											
CHECKED	K.E.M.																											
APPROVED	J.H.																											
DATE	18.11.1985																											
PROJECT NUMBER	21770																											
PROJTRAK NUMBER																												
SIZE	DRAWING No	SHEET	AMD																									
A2	65411	1	5																									