



**NOTES:**

1. EARTH BAR SHALL BE WELDED TO LIGHTNING SPIRE PRIOR TO HOT DIP GALVANISING.
2. WHERE WELDING OR DRILLING IS CARRIED OUT ON SITE ALL WELDS TO BE CLEANED, WIRE BRUSHED, ALL DRILL HOLES CLEANED OF SWARF BEFORE PAINTING WITH COLD GALVANISING PAINT OR EQUIVALENT.

**REFERENCE DRAWINGS**

- FLOODLIGHTING/LIGHTNING SPIRE 2 LIGHT ASSEMBLY GA - 162013
- FLOODLIGHTING/LIGHTNING SPIRE 4 LIGHT ASSEMBLY GA - 169818
- LIGHTNING SPIRE EARTHING DETAILS - 162611

# NETWORK STANDARD

ITEM	DESCRIPTION	QTY.
1	FLAT - 50 x 5 x 340LG AS3679.1-300	1

CAD DRAWING  
DO NOT MANUALLY AMEND  
A M E N D M E N T S  
DWN: AARON BULBERT  
CHKD: BEN STADDON  
APP'D: MICHAEL GRIFFITHS  
DATE: 08/02/2013  
ADDED NOTES 1 & 2



DESIGN & ENGINEERING BRANCH  
145 NEWCASTLE RD WALLSEND, NSW 2287  
Ph 02 4951 9388  
Fax 02 4951 9389

SCALE	1:10
DESIGNED	PETER STOREY
DRAWN	RAY DEAL
CHECKED	PETER STOREY
APPROVED	ROSS HUGHES
DATE	22/10/10
PROJECT NUMBER	STD
PROJTRAK NUMBER	

STANDARD CONSTRUCTION			
LIGHTNING SPIRE EARTH BAR			
DETAILS			
SIZE	DRAWING No	SHEET	AMD
A3	161887	01	1