



ZONE 0 - NO SPECIFIC REQUIREMENTS (PLEASE BYDA)

ZONE 1 - (PLEASE BYDA) EXCAVATION WITH SHORING AS NORMALLY REQUIRED IS ACCEPTABLE (COMPLYING WITH NSW CODE OF PRACTICE FOR EXCAVATION WORK). GAPS BETWEEN THE EXCAVATION WALL AND THE SHORING ARE TO BE FILLED. AUSGRID DOES NOT NEED TO BE CONTACTED.

ZONE 2 - (PLEASE BYDA) AUSGRID MUST BE CONTACTED. EXCAVATION REQUIRES AN ENGINEERED SUPPORT SYSTEM OR PROPRIETARY TRENCH BOX WITH THE GAP BETWEEN EXCAVATION WALL AND SHORING BOX FILLED IN. AUSGRID MAY BE REQUIRED TO HOLD THE POLE DURING EXCAVATION UNTIL THE SHORING BOX IS IN PLACE, AND SIMILARLY FOR SHORING BOX REMOVAL UNTIL BACKFILLING IS COMPLETE.

ZONE 3 - (PLEASE BYDA) AUSGRID MUST BE CONTACTED. SPECIALIST ENGINEERING ADVICE IS REQUIRED BEFORE EXCAVATION IS CARRIED OUT IN THIS ZONE.

CAD DRAWING DO NOT MANUALLY AMEND AMENDMENTS	DWN: GARY HUGHES CHKD: ADAM BRADFORD APP'D: GLENN FORD	DATE: 31/08/2022
		DBYD CHANGED TO BYDA.

1	2	3
---	---	---

NETWORK STANDARD



145 NEWCASTLE RD WALLSEND,  
NSW 2287

SCALE	N.T.S
DESIGNED	A.BRADFORD
DRAWN	P.RIOS
CHECKED	D.STANBURY
APPROVED	G.FORD
DATE	28/02/2022
PROJECT NUMBER	STD
PROJTRAK NUMBER	-

STANDARD CONSTRUCTION EXCAVATION ZONES NEAR AUSGRID POLES			
SIZE	DRAWING No	SHEET	AMD
A3	256262	1	1