

A

A

B

B

C

C

D

D

E

E

F

F

MANUFACTURER'S DRAWINGS FOR CONTRACT EA2081/10

DESCRIPTION	AUSGRID STOCK CODE	AUSGRID DRAWING NUMBER		
		GENERAL ARRANGEMENT	COMPONENT LIST	WIRING DIAGRAM
2000 AMP ACB INCOMING PANEL TYPE 2 (SUBURBAN)	179991	228871	228872	228873
3000 AMP ACB INCOMING PANEL TYPE 1 (CBD MOTORISED) SUPERSEDED BY OAFD VERSION	-	228880	228881	228882
3000 AMP ACB INCOMING PANEL TYPE 1 (CBD MOTORISED) FOR OAFD INSTALLATIONS	179996	228880	234374	
3000 AMP ACB INCOMING PANEL TYPE 2 (SUBURBAN)	179615	228851	228852	228853
3000 AMP ACB BUS SECTION PANEL	179616	228854	228855	228856
FUSED DISTRIBUTOR PANEL - 4 x 400 AMP	179618	228860	228861	228862
FUSED DISTRIBUTOR PANEL - 2 x 400 AMP AND 1 x 800 AMP	179651	228865	228866	228867
FUSED DISTRIBUTOR PANEL - 2 x 800 AMP	179990	228868	228869	228870
DISTRIBUTOR PANEL WITH 2000 AMP DISCONNECTOR AND 1000/1600 AMP FUSE	179993	228874	228875	228876
DISTRIBUTOR PANEL WITH 3000 AMP ACB CONTROLLED CABLE SUPPLY (SUBURBAN)	179617	228857	228858	228859
DISTRIBUTOR PANEL WITH 3000 AMP ACB CONTROLLED BUSBAR SUPPLY (SUBURBAN)	179995	228877	228878	228879
SURGE ARRESTOR AND AUXILIARY FUSE PANEL - LHS	179619	228863	-	228864
SURGE ARRESTOR AND AUXILIARY FUSE PANEL - RHS	180221	228863	-	228864
DISTRIBUTOR PANEL WITH MOTORISED 3000 AMP ACB CONTROLLED CABLE SUPPLY (CBD)	-	244234 Sheet 1	244234 Sheet 2	244234 Sheet 3
DISTRIBUTOR PANEL WITH MOTORISED 3000 AMP ACB CONTROLLED BUSBAR SUPPLY (CBD)	-	244235 Sheet 1	244235 Sheet 2	244235 Sheet 3

AUSGRID DRAWINGS

DESCRIPTION	DRAWING NUMBER
E TYPE LV BOARD ACCEPTABLE COMBINATIONS	178227
E TYPE LV BOARD CLEARANCES, PIT DESIGN AND CONSTRUCTION	178228
E TYPE LV BOARD SUPPORTING STEELWORK GENERAL ARRANGEMENT	178229
E TYPE LV BOARD INSTALLATION OF CABLE LADDER FOR AUXILIARY CABLES	178230

CAD DRAWING  
DO NOT MANUALLY AMEND  
AMENDMENTS  
2. 3000 AMP INCOMING  
PANEL TYPE 1 FOR  
CBD OAFD ADDED.  
P.JARVIS 22/05/2018  
CHECKED: P.TURRIN  
APPROVED: D.GRCEV  
PN: 900029338

3. DISTRIBUTOR  
PANELS WITH 3000  
AMP MOTORISED ACB  
FOR CBD CABLE AND  
BUSBAR SUPPLY  
ADDED. SUBURBAN  
CABLE AND BUSBAR  
DISTRIBUTOR  
PANELS DESIGNATED.  
NON OAFD CBD  
MOTORISED INCOMING  
PANEL SUPERSEDED.  
P.JARVIS 20/05/2019  
CHECKED: P.TURRIN  
APPROVED: M.GIBSON  
PN: 129021840

4. NEW DRAWING  
BORDER ADDED.  
S.MUNRO 18/09/2024  
CHKD: M.BENNETT  
APPR: M.BENNETT



24-28 Campbell Street  
SYDNEY NSW 2000

SCALE	NTS
DESIGNED	P.JARVIS
DRAWN	P.JARVIS
CHECKED	P.TURRIN
APPROVED	M.PEACOCK
DATE	19/08/2010
TRIM REF	-
PROJECT NUMBER	DS 209-1-55-2

E TYPE LV BOARD REFERENCE DRAWING LIST			
SIZE	DRAWING No	SHEET	AMD
A3	215882	1	4