





AUSGRID : 265240-3

REV	DATE	DESCRIPTION	DWN	APP
B	03/07/2023	ADDED GPO	P.W	J.J
A	09/03/2023	INITIAL SCHEMATIC	P.W	J.J

PROJECT: AUSGRID CHAMBER - STOCKCODE: 181834
ASSEMBLY ID: VF223209-AUS07
DESCRIPTION: 2500A TXF DISCONNECTOR + 2x800A S/F + 1x400A F/S
RATINGS: 2000A, 415V, 30ka 3s, FORM 1, IP (NOTE 1)
INSTALLATION TYPE: LV CHAMBER SUBSTATION



WEBER SOUTH PACIFIC PTY LTD
PO BOX 4264 Eight Mile Plains
Queensland Australia
TEL. (07) 3841 6899
FAX. (07) 3841 6877
EMAIL:- sales@webersouthpacific.com.au
THIS DRAWING AND SPECIFICATIONS HEREIN MUST NOT BE
REPRODUCED OR COPIED IN PART OF WHOLE WITHOUT THE
PRIOR PERMISSION OF WEBER SOUTH PACIFIC.

Scale: NTS
DO NOT SCALE
Tolerance: N/A
ALL DIMENSIONS IN MM
UNLESS NOTED OTHERWISE

Standard: AS/NZS 61439.2
Drawing: SCHEMATIC
SHEET 1 OF 1

Client: AUSGRID
Part Number: VF223209-AUS07
Drawing Number: 00015-SC18

Size: A3
Type: 2D
Revision: B

NOT FOR CONSTRUCTION