



**NOTES :**

1. THE FOLLOWING INFORMATION IS OBTAINED FROM THE PROJECT DESIGN DRAWINGS :
  - a. POLE LENGTH AND STRENGTH.
  - b. SPECIAL FOUNDATION REQUIREMENTS.
  - c. POLE EMBEDMENT DEPTH.
  - d. PHASE CONDUCTOR SIZE.
  - e. STAY REQUIREMENTS.
  - f. DEVIATION ANGLE.
  - g. ASSESSED EARTHING REQUIREMENTS.
2. THE MAXIMUM LINE DEVIATION ANGLE TO BE CONSTRUCTED ON THIS ARRANGEMENT IS TO BE DETERMINED BY THE LINE DESIGNER.
3. POLE STEPS ARE TO BE INSTALLED IN ACCORDANCE WITH THE REQUIREMENTS OF NS126.
4. IN AREAS WHERE THE 11KV NETWORK CANNOT BE WORKED ON USING LIVE LINE TECHNIQUES, UNDERBUILT CIRCUITS SHALL BE INSTALLED WITH A MINIMUM CLEARANCE OF 1200mm. IN AREAS WHERE THE 11KV NETWORK CAN BE WORKED ON USING LIVE LINE TECHNIQUES, UNDERBUILT CIRCUITS SHALL BE INSTALLED WITH A MINIMUM CLEARANCE OF 2500mm.
5. THE LOAD AND DEVIATION ALLOWABLE ON THE EYEBOLT IS TO BE DETERMINED FROM DRG : 520324.
6. LONGROD INSULATORS TO BE USED UNDER NORMAL CONDITIONS.
7. POLES SHALL BE DRILLED, SCARFED AND DRESSED ON SITE. DRILLING AND SCARFING TO BE TREATED WITH APPROVED PRESERVATIVES.
8. EYEBOLTS ARE TO BE INSTALLED IN THE DIRECTION OF THE OVERHEAD CONDUCTORS.
9. NON-TENSION COMPRESSION SLEEVES TO BE USED WHEN REQUIRED TO JOIN CONDUCTORS.
10. ALL BOLTS PASSING THROUGH TIMBER ARE TO BE COATED WITH GRAPHITE GREASE.
11. LINE POST INSULATORS ARE TO BE FITTED WHERE LINE DEVIATION IS LESS THAN 90°.

ITEM	DESCRIPTION	DRG. No	STOCK CODE	QTY
11	STEP - POLE, SCREW-IN (SEE NOTE 3)	250144	185198	A/R
10	JOINT - NON TENSION, COMPRESSION (TO SUIT CONDUCTOR)	514053		3
9	CLAMP - CONDUCTOR, ASSEMBLY	508781	H12110	3
8	INSULATOR - 22KV POST, CLAMP TOP, MOUNTED ON GAIN BASE BRACKET		178293	3
7	BOLT & NUT - M20, HEX., GALVANISED (LENGTH TO SUIT POLE)	515466		6
6	INSULATOR - 11/22KV LONGROD, STRING ARRANGEMENT AR-2	565715		6
5	WASHER - FLAT, M20, GALVANISED	518081	177986	12
4	WASHER - CONICAL, M20, GALVANISED	518082	H39655	12
3	WASHER - SQUARE, 75x75x6mm, GALVANISED (Ø22mm HOLE)	518081	H39231	24
2	EYEBOLT - M20, GALVANISED (LENGTH TO SUIT POLE) (SEE NOTES 5 & 8)	513653		6
1	POLE - TIMBER (AS REQUIRED)	513988		1

ALL DIMENSIONS IN MILLIMETRES UNLESS NOTED OTHERWISE. DO NOT SCALE.

CAD DRAWING DO NOT MANUALLY AMEND A M E N D M E N T S DWN: PATRICIA RIOS CHKD: PHIL JONES DATE: 03/09/2007 NOTE 4 AMENDED. APP'D by: STEPHEN CONNOR DWN: PATRICIA RIOS CHKD: PHILLIP JONES DATE: 10/10/2019 M20 WASHER ADDED. INSULATORS UPDATED. NOTES & MATERIAL LIST AMENDED. AUSGRID BORDER ADDED. APP'D by: GLENN FORD	1	2	3
--	---	---	---

NETWORK STANDARD  
  
 145 NEWCASTLE RD WALLSEND, NSW 2287

SCALE	1:25
DESIGNED	PHIL JONES
DRAWN	PATRICIA RIOS
CHECKED	PHIL JONES
APPROVED	STEPHEN CONNOR
DATE	05/12/06
PROJECT NUMBER	STD
PROJTRAK NUMBER	-

STANDARD CONSTRUCTION		11kV VERTICAL TERMINATION	
CONSTRUCTION		2-140	
SIZE	DRAWING No	SHEET	AMD
A3	175875	01	2