



- NOTES :**
- THE FOLLOWING INFORMATION IS OBTAINED FROM THE PROJECT DESIGN DRAWINGS:
 - POLE LENGTH AND STRENGTH.
 - SPECIAL FOUNDATION REQUIREMENTS.
 - POLE EMBEDMENT DEPTH.
 - PHASE CONDUCTOR AND OVERHEAD EARTHWIRE SIZE.
 - VARIATIONS TO STANDARD CROSSARM REQUIREMENTS.
 - STAY REQUIREMENTS.
 - DEVIATION ANGLE.
 - ASSESSED EARTHING REQUIREMENTS.
 - WHEN DESIGNING UNDERBUILT CIRCUITS ON A 33kV STRUCTURE, THE POSSIBLE USE OF LIVE LINE WORKING PROCEDURES MUST BE CONSIDERED WHEN NOMINATING THE CIRCUIT SEPARATION TO ALLOW A MINIMUM CLEARANCE OF 2500mm IF REQUIRED.
 - THE LOAD AND DEVIATION ALLOWABLE ON THE EYEBOLT IS TO BE DETERMINED FROM DRG: 520324.
 - LONGROD INSULATORS TO BE USED UNDER NORMAL CONDITIONS.
 - THE CROSSARM BRACE ATTACHMENT POINT ON A CONCRETE POLE IS TO BE AN M12 STAINLESS STEEL EARTH FERRULE.
 - THE OHEW IS TO BE BONDED TO AN M12 STAINLESS STEEL EARTH FERRULE ON THE CONCRETE POLE.
 - ONLY THE 3000mm STEEL CROSSARM OPTION IS SHOWN ON THIS CONSTRUCTION DRAWING. REFER TO DRG: 237491 FOR DRILLING PATTERN OF ALTERNATE CROSSARM.
 - ONLY THE SINGLE PHASE CONDUCTOR WITH OPGW SPLICE BOX TERMINATION OVERHEAD EARTHWIRE OPTION IS SHOWN ON THIS CONSTRUCTION DRAWING.
 - USE THE OPGW SPLICE BOX TERMINATION ARRANGEMENT WHEN ERECTING AN OPGW OVERHEAD EARTHWIRE. USE THE STANDARD EARTHWIRE TERMINATION ARRANGEMENT WHEN ERECTING A NON OPGW OVERHEAD EARTHWIRE.
 - POLE STEPS SHOULD ONLY BE INSTALLED ON POLES WHERE ACCESS FOR NORMAL MAINTENANCE VEHICLES CANNOT BE MAINTAINED FOR THE LIFE OF THE POLE. IF POLE STEPS ARE INSTALLED, THEY ARE TO COMPLY WITH THE REQUIREMENTS OF NETWORK STANDARD NS128.
 - REFER TO DESIGNER SAFETY REPORT D22/284023 FOR ATYPICAL HAZARDS ASSOCIATED WITH THIS STANDARD CONSTRUCTION.

| | | | |
|----|---|--------|-----|
| 14 | STEP - POLE (SEE NOTE 10) | 514084 | A/R |
| 13 | OPGW - SPLICE BOX & COILED CABLE BRACKET, CONDUCTOR, MOUNTING ARRANGEMENT (USE WITH OPGW OHEW OPTIONS ONLY) | 565743 | 1 |
| 12 | EARTHWIRE - TERMINATION, OVERHEAD, MOUNTING, ARRANGEMENT -2B (SEE NOTES 6, 8 & 9) | 519450 | 1 |
| | OPGW - TERMINATION, CONDUCTOR, MOUNTING, ARRANGEMENT -2B (SEE NOTES 6, 8 & 9) | 565747 | |
| 11 | INSULATOR - LONGROD, 33kV, DUAL CONDUCTOR, POLYMERIC STRING, ARRANGEMENT -3 (SEE NOTES 4 & 8) | 250120 | 1 |
| | INSULATOR - LONGROD, 33kV, POLYMERIC STRING, ARRANGEMENT -3 (SEE NOTES 4 & 8) | 158754 | |
| 10 | INSULATOR - LONGROD, 33kV, DUAL CONDUCTOR, POLYMERIC STRING, ARRANGEMENT -2 (SEE NOTES 4 & 8) | 250120 | 2 |
| | INSULATOR - LONGROD, 33kV, POLYMERIC STRING, ARRANGEMENT -2 (SEE NOTES 4 & 8) | 158754 | |
| 9 | BAND - POLE, MOUNTING & BONDING ARRANGEMENT -1 | 514158 | 1 |
| 8 | WASHER - SQUARE, 75x75x6mm, GALVANISED (Ø22mm HOLE) | 518081 | 2 |
| 7 | WASHER - SPRING, M20, GALVANISED | 518082 | 2 |
| 6 | WASHER - SQUARE, 75x75x6mm, GALVANISED (Ø22mm HOLE) (USE WITH COMPOSITE CROSSARM) | 518081 | 2 |
| | WASHER - LIP, M24, GALVANISED (USE WITH STEEL CROSSARM) | 518081 | |
| 5 | EYEBOLT - M20x200mm, GALVANISED (SEE NOTE 3) | 513653 | 2 |
| 4 | CROSSARM - MOUNTING ARRANGEMENT -1a (GALVANISED STEEL OR COMPOSITE FIBRE CROSSARM) (SEE NOTES 5 & 7) | 514176 | 1 |
| 3 | FOOTING - CONCRETE POLE, ARRANGEMENT (SEE NOTE 1) | 512331 | 1 |
| 2 | EARTHING - CONCRETE/STEEL, SINGLE POLE, BUTT, ARRANGEMENT | 520209 | 1 |
| 1 | POLE - CONCRETE (AS REQUIRED) | | 1 |

ALL DIMENSIONS IN MILLIMETRES UNLESS NOTED OTHERWISE. DO NOT SCALE.

| | |
|--|---|
| CAD DRAWING DO NOT MANUALLY AMEND AMENDMENTS | DWN: GARY HUGHES |
| | CHKD: GARRY CRAIG |
| DATE: 14/10/2013 | AUSGRID BORDER APPLIED. |
| APPD BY: GLENN FORD | |
| DWN: P.R. | |
| CHKD: P.J. | |
| APPD: G.F. | |
| DATE: 08/11/2022 | MULTIPLE CROSSARM OPTION & FOUNDATION DETAILS ADDED. NOTES & MATERIAL LIST AMENDED. DUAL CONDUCTOR & OHEW OPTIONS ADDED. |

| | |
|--|--------|
| COMPOSITE FIBRE CROSSARMS SPECIFICATION | 237491 |
| 20mm EYEBOLT LOADING AND DEVIATION GRAPH | 520324 |
| ASSOCIATED DRAWINGS | |

| | | | |
|--|----------------|------------|---|
| NETWORK STANDARD 145 NEWCASTLE RD WALLSEND, NSW 2287 | SCALE | 1:25 | STANDARD CONSTRUCTION 33kV DELTA TERMINATION CONSTRUCTION WITH OVERHEAD EARTHWIRE 4-25C/E |
| | DESIGNED | PHIL JONES | |
| DRAWN | P.RIOS | | |
| CHECKED | PHIL JONES | | |
| APPROVED | STEPHEN CONNOR | | |
| DATE | 20/12/2007 | | |
| PROJECT NUMBER | STD | | |
| PROJTRAK NUMBER | - | | |
| SIZE | A2 | DRAWING No | 174243 |
| SHEET | 1 | AMD | 2 |