



AT CABLE JOINT WHERE PARALLEL TO ADJACENT CABLES

AT CABLE JOINT WHERE PERPENDICULAR TO ADJACENT CABLES

1 SECTION
252098 SCALE 1:20

FOR PROMATECT-L BOARDS AND FIXING DETAILS REFER TO DRAWING No. 252111

NOTES:

1. ALL TRAYS ABOVE JOINT AND WITHIN THE ZONE OF INFLUENCE TO BE PROVIDED WITH 20mm THICK PROMATECT-L BOARDS AS SHOWN.
2. TRAY IMMEDIATELY BELOW JOINT TO BE PROVIDED WITH 20mm THICK PROMATECT-L BOARD (TOP ONLY) AS SHOWN
3. CABLE BLANKET PROTECTION ALSO APPLIES TO SECONDARY CABLES
4. NO CABLE BLANKETS TO BE PLACED AROUND CABLE JOINTS.
5. REFER TO 252098, 252100, 252101 AND 252111 FOR DETAILS
6. NOTIFY CABLE RATINGS SECTION THAT CABLES ARE COVERED - ENTRY INTO GIS IS REQUIRED.
7. FOR STANDARD DESIGN AND SAFETY NOTES REFER TO TRIM REFERENCE D20/295304

AMENDMENTS

AMD	DATE	DESCRIPTION	DRAWN BY	DESIGNED BY	CHECKED BY	APPROVED BY
0	29.06.20	CONSTRUCTION ISSUE	J.ABDILLA	T.VELONAS	J.METTI	K.GALLEN
1	16.09.20	TRIM REFERENCE REVISED	J.ABDILLA	T.VELONAS	J.METTI	K.GALLEN

CAD DRAWING DO NOT MANUALLY AMEND AMENDMENTS



ISSUED FOR CONSTRUCTION

SCALE	AS SHOWN
DESIGNED	TASS VELONAS
DRAWN	JOSEPH ABDILLA
CHECKED	JOE METTI
APPROVED	KATINA GALLEN
DATE	06.07.20
TRIM REF	2019/26353

**CABLE BLANKET FIRE PROTECTION
POWER AND SECONDARY CABLES
NEAR CABLE JOINTS
SECTION AT CABLES ON TRAYS
SHEET 2**

PROJECT NUMBER	SJ-00313	SIZE	A3	DRAWING No	252099	SHEET	1	AMD	1
----------------	----------	------	----	------------	--------	-------	---	-----	---